

ADDENDUM NO. 1
FOR
GURLEY SRF WASTEWATER COLLECTION AND TREATMENT IMPROVEMENTS
FOR
THE TOWN OF GURLEY
MARCH 28, 2018

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. Reference Part VI, Technical Specifications, Division No. 11 – Equipment, Specification Section 11311 – Submersible Sewage Pump Facility, Paragraph 2.01.C., Page 11311-2.
 - A. Equal manufacturers listed in Paragraph 2.01.C. also include Hydromatic.

- II. Reference Part VI, Technical Specifications, Division No. 11 – Equipment, Specification Section 11311 – Submersible Sewage Pump Facility, Paragraph 2.03.A., Page 11311-4.
 - A. The following is hereby added to the specifications as Paragraph 2.03.A.9:

9. Enclosure latching device shall be a single stainless steel L-handle with 3 point latch. Clamps are not acceptable.

- III. Reference Drawings, Plan Sheet 4.
 - A. The notes and descriptions on Sheet 4 shown in note clouds depict the work that will be performed as a part of the project. The other notes and descriptions are for information only to provide an understanding of the existing WWTP facility and operations.

- IV. Reference Drawings, Plan Sheet 4.
 - A. The word “**PROPOSED**” is hereby removed from the description of the 20’ x 24’ covered sludge storage shed on Plan Sheet 4. The shed is not a part of the project.

V. Reference Drawings, Plan Sheet 7.


- A. Note No. 9 on Plan Sheet 7, referencing to seal all leaks, is hereby changed from "MANHOLE" to "**WETWELL**". Sealing all existing leaks in the manhole is covered under Note No. 15.

VI. Reference Drawings, Plan Sheet E-02.

- A. The label for the existing electrical pole and control panel picture detail is hereby changed from "EXISTING PUMP STATION NO. 8" to "**EXISTING PUMP STATION NO. 4**". The picture and notes refer to Pump Station No. 4.

THIS ADDENDUM ISSUED THIS 28th DAY OF MARCH, 2018.

LADD ENVIRONMENTAL CONSULTANTS, INC.



Adam J. Lea, P.E.