

ADDENDUM NO. 3
FOR
MAINTENANCE BUILDING
FOR
WATERWORKS BOARD OF THE TOWN OF RAGLAND

SEPTEMBER 26, 2018

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. Reference Plans, Sheet 1
 - A. On Site Plan, the total length of fence required is 272 LF, including the length of gates.
 - B. The divider fence that connects to the center of the building is shown as three lines. A single fence only is required here.

- II. A source of chert is available to the Contractor at no charge from quarries owned by National Cement. The Contractor is responsible for hauling. Quarries are located off of Highway 144 South of Ragland and at Gardner Road and Martin Crossing Road near Highway 144 East of Ragland.

- III. The Owner will pay the cost of all concrete, to be supplied by Kirkpatrick. Bidders are advised to NOT include the cost of concrete as a material in the bid price. Contractor is responsible for ordering and coordination of delivery of concrete, but cost will be billed by Kirkpatrick to Owner. The cost of any admixtures will NOT be paid by the Owner but would be the responsibility of the Contractor.

THIS ADDENDUM ISSUED THIS 26th DAY OF SEPTEMBER 2018.

LADD ENVIRONMENTAL CONSULTANTS, INC.


James Payton, P.E.