

**ADDENDUM NO. 1**  
**FOR**  
**PLAYGROUND RENOVATION AT CHEAHA STATE PARK**  
**FOR THE**  
**ALABAMA DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES**  
**LWCF PROJECT NO. 14-LW-1001**  
**DCNR PROJECT NO. 18-P-52**  
**BC PROJECT NO. 2019052**

**FEBRUARY 28, 2019**

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. Reference Part V – Special Conditions, Page V-5, Paragraph 13
  - A. Add the attached sample “Buy America Certification” letter included on page ADM 1-3 to the Contract Documents. This letter may be used to comply with the certification required in Paragraph 13.C.
  
- II. Reference Part VI – Technical Specifications, Division No. 2 – Sitework, Section 02229 – Rock Removal
  - A. Blasting is prohibited on this project. All rock removal shall be by mechanical means only.
  
- III. Reference Plans, Sheet 1
  - A. The two electrical panels located to either side of the playground and shown on Sheet 1 as (E) will be removed by the Owner prior to commencement of construction.
  - B. Tree removal is to be performed by the Contractor per Note No. 9. Contractor shall dispose of trees off-site at Contractor’s expense. Where stumps are not beneath concrete or equipment footers and may remain in place, they shall be removed below finished grade level prior to installation of rubber mulch.
  - C. A water line is located adjacent to the paved road and the parking area and part of the sidewalk will be installed over the water line.
  
- IV. Reference Plans, Sheet 4
  - A. The LWCF Park Sign Support Detail B shows a 3 foot bury depth for posts. The location of the post will be selected by the Owner but may be varied as required to avoid rock, provided similar sight lines are maintained and the location does not interfere with other uses of the site. Contractor may also shorten the bury

depth when on solid rock by providing bolted connection into solid rock. At a minimum, 1/2" diameter anchors, 3 inch embedment, 4 per post with 3/8" steel plate connected to rock. Plate shall connect to 3/8" thick steel cap that post will sit in for a minimum 3 inches. Screws shall connect cap to post.

- V. The following Pre-Bid Minutes are included by Addendum and are made a part of the Contract Documents.
- A. A Pre-Bid Conference was held on Tuesday, February 26, 2019 at the Cheaha State Park, Cleburne Room at 1:00 PM CST. James Payton with Ladd Environmental Consultants, Inc. moderated the conference. An attendance list is attached on page ADM1-4.
  - B. A general description of the project was presented including that the total disturbed acreage is less than 1 acre (plan sheet 1). Work schedule is Monday – Friday, 40 hours per week and work on weekends and holidays is not permitted unless specific permission is granted due to extenuating circumstances, (Part V Special Conditions, Page V-2, Paragraph 2). Traffic control is the contractor's responsibility (Part V Special Conditions, Page V-4, Paragraph 10). Buy America requirements were discussed as detailed in Part V Special Conditions, Page V-5, Paragraph 13. Buy America is an integral part of this project and payment will not be approved without proper certification by the Contractor.
  - C. A question was asked about what must be submitted with the bids. Part II of the Contract Documents must be submitted.
  - D. A question was asked about rock excavation. There is not a separate payment or unit price for rock removal; all costs shall be included in the bid items. Notes in the plans indicate that, when bearing on rock, certain concrete and subsoil may be eliminated.
  - E. A question was asked about pre-approved suppliers. Any suppliers submitting information that can be pre-approved will be issued by addendum.
  - F. A question was asked about testing. The Contractor pays for all testing.
  - G. A question was asked about a sign. The Contract Documents require a project sign for all projects over \$100,000.00 that is separate from the wooden sign support in the project.
  - H. The project area was walked by all in attendance.

THIS ADDENDUM ISSUED THIS 28<sup>th</sup> DAY OF FEBRUARY 2019.

LADD ENVIRONMENTAL CONSULTANTS, INC.



James Payton, P.E.



<company letterhead>

## Buy America Certification

Project Name: \_\_\_\_\_

Project Description: \_\_\_\_\_

The undersigned hereby certifies on behalf of itself and all contractors (at all tiers) that it has met Buy America requirements in 23 CFR 635.410, based on the following provision:

<Choose ONE of the following, delete the one that does not apply>

**The product(s) below contains no steel or iron products manufactured outside the United States.** To be considered domestic, all steel and iron used and all products manufactured from steel and iron must be produced in the United States and all manufacturing processes, including application of a coating, for these materials must occur in the United States. Coating includes all processes that protect or enhance the value of the material to which the coating is applied.  
<If there is ANY foreign steel or iron in your product you may not select this option.>

**The product(s) below has minimal use of steel or iron products manufactured outside the United States.** The Buy America regulation does "not prevent a minimal use of foreign steel and iron materials, if the cost of such materials used does not exceed one-tenth of one percent (0.1 percent) of the total contract cost or \$2,500, whichever is greater." For purposes of this certification, the cost is that shown to be the value of the steel and iron products as they are delivered to the project. Detailed documentation indicating that this requirement is met is attached.

This certification applies to the following products: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

The undersigned acknowledges that a false certification is a criminal act in violation of 18 USC 1001 and that should this Agreement be investigated, the undersigned has the burden of proof to establish that it is in compliance.

Contractor: \_\_\_\_\_

Signature of Authorized Official: \_\_\_\_\_

Printed Name of Authorized Official: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

**ADDENDUM NO. 1**

## **Pre-Bid Conference Attendees**

James Payton	Ladd Environmental Consultants Inc.
Duane Stephens	Hurst Construction
Ken Thomas	Alabama State Parks
Jeffery Thomas	Alabama State Parks
Kight Jones	J.A. Dawson & Co.
Sonny Foster	Alabama State Parks
Mike Waldrup	Alabama State Parks – Cheaha
Kyle Kinman	Alabama State Parks
Kelly B. Ezell	Alabama State Parks
Renee Raney	Alabama State Parks
Scott Keen	Splanh Construction
Jamie Rollins	Hurst Construction