

ADDENDUM NO. 1
FOR
TRAIL HEAD RESTROOMS AND PARKING FACILITIES
AT
WEATHINGTON PARK
SECTION, ALABAMA
RTP PROJECT NO. 19-RT-53-01

MAY 20, 2019

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

I. Reference Plans, Sheet 2, General Notes

A. Delete Note No. 6 regarding ceiling fresh air intake.

II. Reference Plans, Sheet No. 4, Detail G/4.

A. Delete "Grassing to be Performed by Owner." Topsoil, finished grading and grassing are all included in the Contract.

III. Reference Plans, Sheet E-1

A. The following schedule shall apply for exhaust fans used on the project:

1. EF-1 and EF-2

a. Cook Model GC-166.

b. 133 CFM.

2. EF-3

a. Cook Model GC-146.

b. 77 CFM.


3. EF-4

a. Cook Model GC-128.

- b. 52 CFM.
- 4. General Requirements
 - a. Ceiling mounted.
 - b. Direct drive.
 - c. 120V/1 Phase/60 Hz.
 - d. Disconnect required.
 - e. Back-draft damper required.
 - f. Controlled by switch with lights.
 - g. Color to be selected by Owner.
- B. Exhaust fans shall be vented through the roof.
- C. The following schedule shall apply for electric unit heaters used on this project:
 - 1. EH1, EH-2, EH-3 and EH-4.
 - 2. TPI Model E30350WBW.
 - 3. 1500 W.
 - 4. 120V/1 Phase/60 Hz.
 - 5. Wall mount thermostat with locking metal thermostat guard, Stelpro No. F290193 required.

THIS ADDENDUM ISSUED THIS 20th DAY OF MAY, 2019.

LADD ENVIRONMENTAL CONSULTANTS, INC.



Adam Lea, P.E.

