

ADDENDUM NO. 2
CONTRACT NO. 1 – CROSSVILLE WATER TREATMENT IMPROVEMENTS
FOR
THE CROSSVILLE WATER BOARD
DW ARPA PROJECT NO. FS010407-01

DECEMBER 9, 2024

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

I. Reference Electrical Plans

- A. Sheet E-2 Treatment Plant Plan – Electrical: At Dualator III Filter, change text currently reading “3#14, 1#14G, 0.5” ” to read “NOTES 5, 7”.
- B. Sheet E-2 NOTES: Add Note 7 reading “7. Provide local disconnect at each Valve Actuator Motor in accordance with the requirements of NEC Article 430 (Note: 430.102 Exception #3 does not apply).”

THIS ADDENDUM ISSUED THIS 9TH OF DECEMBER 2024.

LADD ENVIRONMENTAL CONSULTANTS, INC.

Adam Lea, P.E.

