

ADDENDUM NO. 3**CONTRACT NO. 1 – CROSSVILLE WATER TREATMENT IMPROVEMENTS****FOR****THE CROSSVILLE WATER BOARD****DW ARPA PROJECT NO. FS010407-01****DECEMBER 10, 2024**

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

I. Reference Plans – Sheet 4

- A. The dimension north of the air wash blower to the control panel shall be 3'-0" minimum.
- B. The dimension from the air wash blower to the south wall shall be deleted.
- C. Between the 150 GPM pump and the existing 4" Check Valve the words "Mag Meter" shall be called out on the piping to label the mag meter, as shown.

II Reference Plans – Sheet 7

- A. The words "Ultrasonic Flow Meter" shown on Sheet 7 shall be replaced with the words "Mag Meter."

THIS ADDENDUM ISSUED THIS 10TH OF DECEMBER 2024.

LADD ENVIRONMENTAL CONSULTANTS, INC.



Adam Lea, P.E.

