

ADDENDUM NO. 1**CONTRACT NO. 1 – WATER SYSTEM REHABILITATION AND IMPROVEMENTS,****TANK REHABILITATION****FOR****THE CROSSVILLE WATER BOARD****DW ARPA PROJECT NO. FS010407-01****NOVEMBER 27, 2024**

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. The following questions were received from plan holders. Responses are included:
1. Question: Will we have access to power and water at both sites while performing the project? Response: At the 250,000 gallon tank, both water and power are not available on-site. At the smaller 50,000 gallon tank, power is available but water is not available on-site.
 2. Question: Does either tank have any antennas? If so, will they be removed prior to the start of work? Response: Refer to the inspection reports in the Exhibits. Nothing on the tanks at bid time will be removed from the tank prior to rehabilitation.
 3. Question: Is there an estimate or budget for this project? Response: The estimate is \$290,000 for each tank. There is a second contract being bid at the same time for filter upgrades, and the decision of which schedule to award will depend partially on the bids received on that contract compared to available funds.
 4. Question: Who will be inspecting this project? Will there be a third-party inspector? Response: Tank inspections will be performed by Ladd Environmental Consultants and Mid-South Tank Consultants.
 5. Question: Will the owner pull the water samples and pay for Bac-T? Response: The Owner will pull water bacteriological water samples and pay for the testing. Any re-testing required due to failed tests will be paid for by the Contractor.

THIS ADDENDUM ISSUED THIS 27TH OF NOVEMBER 2024.

LADD ENVIRONMENTAL CONSULTANTS, INC.

James Payton
James Payton, P.E.

