

ADDENDUM NO. 2
FOR
SEWER SYSTEM UPGRADES
FOR
TOWN OF LEESBURG
DW ARPA PROJECT NO. FS010428-01

MAY 15, 2025

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

I. Reference Part V – Special Conditions, Paragraph 33, Page V-13

- A. A Construction Best Management Practices Plan (CBMPP) has been prepared by the Engineer to assist the Contractor in obtaining an NPDES Stormwater Permit for construction activities. The CBMPP is available for review to all Bidders upon request.

II. Reference Plan Sheet 3

- A. The bore across Canal Street for the 4" force main along Hale Drive is hereby changed to 10" casing in lieu of the 8" casing shown. This Plan change will match the Bid Schedule quantities.

THIS ADDENDUM ISSUED THIS 15TH DAY OF MAY 2025.

LADD ENVIRONMENTAL CONSULTANTS, INC.



Adam Lea, P.E.

