

**ADDENDUM NO. 1**  
**FOR**  
**SEWER SYSTEM UPGRADES**  
**FOR**  
**TOWN OF LEESBURG**  
**DW ARPA PROJECT NO. FS010428-01**  
  
**APRIL 23, 2025**


TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. Reference Part VI, Division No. 11, Specification 11325, Page 11325-6, 11325-10 and 11325-11
  - A. Add Paragraph 2.11.C.5 and 2.11.C.6 as follows:
    5. *Enclosure shall be UL rated, NEMA 4X weatherproof, tamperproof, raintight, designed for mounting in unprotected outdoor location. Constructed of stainless steel.*
    6. *Enclosure shall have a gasketed, hinged front, all-weather, door handle opened with locking capability and an internally mounted hinged dead front panel. All major components and sub-assemblies shall be identified as to function with laminated, engraved bakelite nameplates.*
  - B. The Myers pump model list in Paragraph 3.07.A.1. shall be: *Myers Model No. WG100H-23.*
  - C. The rail base model listed in Paragraph 3.07.A.11. shall be: *Myers Model No. SRA23HH.*

THIS ADDENDUM ISSUED THIS 23<sup>RD</sup> DAY OF APRIL 2025.

LADD ENVIRONMENTAL CONSULTANTS, INC.

  
\_\_\_\_\_  
Adam Lea, P.E.

