

ADDENDUM NO. 2
FOR
CONTRACT NO. 2 – WASTEWATER GRAVITY SEWER
REHABILITATION AND EXTENSION
FOR
THE CITY OF RAINSVILLE
CW ARPA PROJECT NO. CS010257-05

AUGUST 10, 2026

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. Reference Part II, Contract Documents, Bid Schedule, Page II-2 and Explanation for Bid, Page II-4 and Part VI – Technical Specifications, Division No. 2- Sitework, Section 02762 – Sanitary Sewer Cleaning and Television Inspection.
 - A. In Bid Item No. 2, cleaning of sewer lines shall include up to two (2) passes with a jetter during cleaning operations. Additional efforts to remove any remaining roots or grease or any heavy cleaning are not required.

THIS ADDENDUM ISSUED THIS 10TH OF AUGUST 2026.

LADD ENVIRONMENTAL CONSULTANTS, LLC


James Payton, P.E.

