

ADDENDUM NO. 1
FOR
FORCE MAIN EXTENSION TO MARTIN LANE
FOR
THE CITY OF RAINSVILLE

AUGUST 14, 2026

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications and Contract Documents are hereby amended, modified, and changed as follows:

I. Reference all Plan Sheets

- A. HDPE with a pressure class of 200 PSIG meeting the specification in 02733 paragraph 2.01 C is an acceptable substitution for all PVC class 200 shown on the plans.
- B. Directional boring is an acceptable alternative to dry bores shown on the plans. Directional bores shall maintain 36"-48" of cover below the existing grade.

II. Reference Specification 02115

- A. A CBMPP has been prepared and is available upon request.

THIS ADDENDUM ISSUED THIS 14th DAY OF AUGUST, 2026.

LADD ENVIRONMENTAL CONSULTANTS, LLC

James Payton

James Payton, P.E.

