

ADDENDUM NO. 2
FOR
RESURFACING AND DRAINAGE IMPROVEMENTS
ALONG SEWELL FERRY ROAD AND HIDDEN COVE CIRCLE
FOR
THE TOWN OF CEDAR BLUFF
SEPTEMBER 4, 2026

TO: ALL PLAN HOLDERS AND INTERESTED PARTIES

SUBJECT: Plans, Specifications, and Contract Documents are hereby amended, modified, and changed as follows:

- I. Reference Part II, Explanation of Bid Form, Paragraph G.2., Page II-6
 - A. Add the following Paragraph G.2.d to the Explanation of Bid Form:
 - d. *Clearing shall include only brush and limb removal as required to establish ditches. Tree removal is not included.*
- II. Reference Part VI, Technical Specifications, Division No. 2 – Sitework, Section 02956 – Bio-Degradable Erosion Control Blanket (SC 150 BN)
 - A. Specified erosion control blanket is equivalent to ALDOT Bid Item 659C-003 – Erosion Control Product, Type S1 with a longevity of 18 months or greater.
- III. Reference Plan Sheet 8
 - A. Add the following Note No. 8 to Plan Sheet No.8.
 8. *Drives in the elevated roadway section shall be brought to the new road level by elevating the drive at a slope of 6% to connect the new road. Build up shall be chert with 4" of CABC, Plant Mix, Type B surfacing. Drives shall have the elevated section paved with a minimum of 220#/SY of wearing surface.*

THIS ADDENDUM ISSUED THIS 4TH DAY OF SEPTEMBER, 2026.

LADD ENVIRONMENTAL CONSULTANTS, LLC



Adam Lea, P.E.

ADM2-1

